

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 3725-0139:126 Page 1 of 1

CATEGORY: Door Hardware (Fire-rated)

LISTEE: Von Duprin, 2720 Tobey Dr., Indianapolis IN 46219
Contact: Roger Vitt (317) 613-8944

DESIGN Models 9475-F and 9575-F, EL9475-F, EL9575-F mortise type fire exit hardware. The hardware consists of a horizontal push bar with a center case. Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number and UL label.

APPROVAL: Listed as fire exit hardware for use on swinging 3-hour, 1-1/2-hour and 3/4-hour single outwardly swinging doors or on the active leaf of a pair of doors. Units are intended for use on doors measuring up to 4' wide and 10' high for single and 8' x 10' for double.

10-29-2001



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 8, 2002

*Listing Expires **June 30, 2003***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager